

# Water/Wastewater Operational Summary

## (November 2016)

Production						
Murphree Water Treatment Plant						
	November 2016 (mgd)	FY to Date (mgd)	Permitted Capacity (mgd)	% of Permitted Capacity	Status	
Average Daily Flow	23.9	23.7	30	79%	Green	
	Peak Daily Flow	27.2	27.2	54	-	Green
Main Street Water Reclamation Facility						
	November 2016 (mgd)	FY to Date (mgd)	Permitted Capacity (mgd)		Status	
Average Daily Flow	5.5	6.1	7.5		Green	
Kanapaha Water Reclamation Facility						
	November 2016 (mgd)	FY to Date (mgd)	Permitted Capacity (mgd)		Status	
Average Daily Flow	10.5	10.8	14.9		Green	
Water Reclamation Facilities (Combined)						
	November 2016	FY to Date (mgd)	Permitted Capacity (mgd)	% of Permitted Capacity	Status	
Average Daily Flow	16.0	16.9	22.4	75%	Green	
Maintenance						
Wastewater Collections			Nov 2016 (miles)	YTD	Monthly Goal (mile)	Status
Miles of gravity mains cleaned			5.7	13.1	7.5	Yellow
Miles of gravity mains TV inspected			5.1	12.5	7.5	Yellow
Water Distribution & Wastewater Collections			November 2016	YTD	Status	
Work orders, service orders completed			1124	2011	Green	