

Water/Wastewater March Dashboard

Production

Murphree Water Treatment Plant

		Mar 2019	FY to Date (mgd)	Permitted Capacity (mgd)	% of Permitted Capacity	Status
	Average Daily Flow	23.0	22.1	30	74%	
	Peak Daily Flow	26.5	24.9	54	-	

Main Street Water Reclamation Facility

		Mar 2019	FY to Date (mgd)	Permitted Capacity (mgd)		Status
	Average Daily Flow	5.9	6.6	7.5		

Kanapaha Water Reclamation Facility

		Mar 2019	FY to Date (mgd)	Permitted Capacity (mgd)		Status
	Average Daily Flow	11.9	12.1	14.9		

Water Reclamation Facilities (Combined)

		Mar 2019	FY to Date (mgd)	Permitted Capacity (mgd)	% of Permitted Capacity	Status
	Average Daily Flow	17.8	18.7	22.4	83%	

Maintenance

Wastewater Collections

		Mar 2019 (Miles)	FYTD	Monthly Goal (miles)	
	Miles of gravity mains cleaned	7.2	38	5.0	
	Miles of gravity mains TV inspected	2.8	32	5.0	

Water Distribution

		Mar 2019	FYTD	Monthly Goal	
	Number of Water Services Replaced	84	462	75	

SSO Monthly Summary

		March	YTD	GOAL	
	Sanitary Sewer Overflows	3	13	<16	