

Power 2020

A plan to best meet GRU's obligation to the reliability of the bulk electric system (BES) of The State of Florida and best serve the needs of GRU's customers.

Item #130957
Regional Utilities Committee
September 11, 2014



Power 2020 will Consider:


- Seasonal, daily and hourly customer demand
- Future regulatory (EPA, NERC) constraints
- GRU generation assets
- The GRU transmission & distribution systems
- Current purchase power obligations (GREC)
- Future purchase power opportunities
- Distributed Energy Resources (DER)
- Demand side load management
- Asset aggregation

What is significant about 2020?

- Not so far out on the planning horizon that dealing with ramifications can be delayed
- Far enough out on the planning horizon that there is time for action
- GRU's current coal transportation contract runs out on December 31, 2019 and the "as delivered" cost of coal will likely increase
- EPA Existing Source Performance Standard (ESPS)/CO₂ Building Blocks #1 & #2 Compliance Year

Current & Evolving Situation Demand Characteristics

GRU Demand
August 5, 2013



Current & Evolving Situation Generation

(in GRU Service Territory; GRU + GREC + DER)

- GRU is currently long in base load generation beyond the planning horizon
- DH 2 required to perform intermediate service
 - Deep load cycling
 - Seasonal cold standby (CSB)
 - Gas –vs- coal price dependent
- EPA ESPS/ CO₂ Emissions from Power Plants
 - Potential Off/On Cycling of Deerhaven 2
- Increasing intermittent distributed generation (solar)


Current & Evolving Situation Generation

| <u>Plant / Unit</u> | <u>Primary Fuel</u> | <u>Net Summer Capability (MW)</u> |
|--------------------------------------|------------------------------|-----------------------------------|
| GREC | Waste Wood | 102.5 |
| J R Kelly Combine Cycle 1 | Natural Gas | 112.0 |
| Deerhaven Generating Station ST 2 | Coal | <u>232.0</u> |
| Deerhaven Generating Station ST 1 | Natural Gas | 75.0 |
| Deerhaven Generating Station CT 3 | Natural Gas | <u>75.0</u> |
| Deerhaven Generating Station CT 1 | Natural Gas | 17.5 |
| Deerhaven Generating Station CT 2 | Natural Gas | <u>17.5</u> |
| South Energy Center | Natural Gas | <u>4.1</u> |
| | Base Capacity | 446.5 |
| | Intermediate Capacity | 150.0 |
| | Peaking Capacity | 35.0 |
| | Total Capacity | <u>635.6</u> |

Note: All time Peak Load was 484 mw, served in 2007

Current & Evolving Situation Transmission

- Three GRU ties with Duke, one with FPL
- Option to serve load with imported power
 - Existing ties will not reliably support serving load solely by imported power
 - Above 375 MW load, loss of one tie would overload GRU and FPL or Duke
 - Currently must have generation in GRU service territory



Current & Evolving Situation Distributed Generation

- Solar generation in GRU's service territory will continue to increase
 - Intermittency requires quicker system generation response to follow load
- Expectation that other forms of DER will enter the mix
 - Fuel cells? ...Wind?
- Potential for mutually beneficial operation of standby generation

Current & Evolving Situation

Demand Side Management

- DSM is a net negative air emissions alternative to generation
 - It can be a low cost alternative in meeting reserve calls
 - It can reduce peak load generating requirements
- GRU has no active DSM
 - DSM is a “Building Block” in the ESPS/CO₂

Current Activities/Next Steps

- Formalizing Team Members and Organization Design
- Developing overall scope & schedule of Power 2020 (est. draft report by 9-30-15)
 - Incorporate ESPS/CO₂
- Identifying internal resources
- Determining Task Assignment for consultant(s)
- Received DEP Construction Permit for 50 MW of peaking power in 2018-19
 - Place holder to establish air emissions cap
- Simulation of alternative scenarios

POWER 2020

