

Current vs. Proposed Local Limits		
Parameter	Current Limit mg/L	Proposed Limit mg/L
Plant Independent		
Arsenic	0.15	0.15
Barium	450	300
Cadmium	0.08	0.08
Chromium	3	3
Copper	0.5	0.5
Iron	100	100
Lead	0.2	0.2
Manganese	7	7
Mercury	0.0002	0.0002
Molybdenum	0.35	0.35
Nickel	0.8	0.8
Selenium	0.15	0.1
Silver	0.1	0.1
Zinc	2.5	2.5
Cyanide	0.15	0.1
Fluoride	20	20
pH lower limit	5.5	5.5
pH upper limit	11	11
Oil & Grease	100	100
Plant Specific Limits		
<u>Kanpaha WRF</u>		
CBOD	None	5,000
TKN	None	800
TSS	None	1,000
<u>Main Street WRF</u>		
CBOD	None	2,000
TKN	None	350
TSS	None	1,000