

Appendix A: Technical Review Comments

Comment	Date	Reviewer
<p>1. Please add a note to the cover sheet: The owner or the owner's authorized agent shall develop a fire safety program to address all essential fire and life safety requirements for the duration of demolition, alteration and construction. As specified in the Florida Fire Prevention Code, including NFPA 241, the fire safety program shall include an emergency response plan, as well as identifying fire prevention precautions, site and building emergency access routes, temporary and permanent water supplies, building egress routes, good housekeeping practices, and fire protection system installation and maintenance. [Gainesville Fire Prevention and Protection Code Section 10-9 (NFPA 1-16)]</p>	3/6/17	Tom Burgett (Fire Department)
<p>Please add a note to the cover sheet: The development shall comply with The Florida Fire Prevention Code. [Gainesville Fire Prevention and Protection Code Section 10-5(a) & (b)]</p>	3/6/17	Tom Burgett (Fire Department)
<p>Please let's meet on site to see how the existing trees will be impacted by the seasonal and trailer display and the fenced bull pen areas</p>	2/17/17	Earline Luhrman (Urban Forestry)

Transferred from ProjectDox 3/22/2017