LEGISLATIVE # 140495A

ORDINANCE NO. 140495

3 An ordinance of the City of Gainesville, Florida, amending the Code of 4 Ordinances relating to fire prevention and protection; amending Section 2-5 339 related to civil citations for fire prevention and protection; amending 6 Sections 10-9 through 10-13 to provide for local amendments to the Florida 7 Fire Prevention Code; amending Sections 10-15 through 10-18 to update 8 provisions related to emergency access to gated developments and restricted 9 access occupancies; amending Sections 10-36, 10-38, 10-40, and 10-41 to 10 update provisions related to false fire alarms; amending Sections 10-50 and 10-51 to update provisions related to assembly occupancy safety; amending 11 12 Sections 10-61, 10-63, 10-64, 10-66, and 10-68 to update provisions related to open and outdoor burning; amending Appendix A. Schedule of Fees, Rates 13 14 and Charges related to Fire/Rescue; providing directions to the codifier; 15 providing a severability clause; providing a repealing clause; and providing an immediate effective date. 16

1

2

17

18 WHEREAS, Article VIII, Section 2, Florida Constitution and Chapter 166, Florida 19 Statutes, confers upon municipalities the authority to conduct municipal government and to enact 20 legislation designed to promote the public health, safety, and general welfare of its citizenry; and 21 WHEREAS, Chapter 633, Florida Statutes, was adopted by the Florida Legislature to 22 provide a mechanism for the State Fire Marshal to adopt a uniform, statewide Florida Fire 23 Prevention Code, which shall contain uniform firesafety standards, all firesafety laws and rules 24 that pertain to and govern the design, construction, erection, alteration, modification, repair, and 25 demolition of public and private buildings, structures, and facilities, and the enforcement of such 26 firesafety laws and rules; and

- WHEREAS, Section 633.202, Florida Statutes, requires the State Fire Marshal to adopt
 an updated *Florida Fire Prevention Code* every three years; and
- WHEREAS, Section 633.202, Florida Statutes, allows municipalities to adopt local amendments to the *Florida Fire Prevention Code* that provide a higher degree of lifesafety and firesafety and that shall be effective only until the State Fire Marshal's adoption every third year of a new edition of the *Florida Fire Prevention Code*, at which time municipalities may readopt

1	local amendments; and			
2	WHEREAS, the State Fire Marshal has filed with the Department of State for the			e for the
3	adoption of the 5 th Edition of the Florida Fire Prevention Code, with an effective date of			
4	Decembe	December 31, 2014; and		
5	W	HEREAS, this ordinance adopts local amendments to and suppleme	nts the	Florida
6	Fire Prevention Code by affording the citizens of Gainesville with a higher degree of lifesafety			ifesafety
7	and firesafety related to ensuring an adequate water supply for firefighting, fire alarm reduction,			eduction,
8	open burning and assembly occupancy safety; and			
9	WHEREAS, at least ten (10) days' notice has been given once by publication in a			
10	newspaper of general circulation notifying the public of this proposed ordinance and of public			
11	hearings in the City Hall Auditorium located on the first floor of City Hall in the City of			City of
12	Gainesvil	lle; and		
13	WHEREAS, public hearings were held pursuant to the notice described above at which			
14	hearings the parties in interest and all others had an opportunity to be and were, in fact, heard.			
15	NOW, THEREFORE, BE IT ORDAINED BY THE CITY COMMISSION OF THE			
16	CITY OF GAINESVILLE, FLORIDA:			
17	S	ection 1. The portion of Section 2-339 of the City of Gainesville Code	e of Or	dinances
18	that pertains to violations of Chapter 10 of the Code is amended as follows. Except as amended			
19	herein, the remainder of Section 2-339 remains in full force and effect.			
20	Sec. 2-33	9 Applicable codes and ordinances.		
21 22	The follo	wing ordinances are enforceable by the procedures described in this divis	sion:	
	Section	Description	Class	Penalty
	Chapter 10	All adopted fire prevention & protection codes, except NFPA 101 Chapters 5, 6, 7 and SFPC Chapters 6, 8, 31 and 42 All adopted fire	Π	\$250.00

2

	prevention and protection codes inclusive of the Florida Fire		
	Prevention Code.		
10-38(a)	Failure to register—fire alarm contracting or monitoring company	Ħ	\$125.00
10-38(d)	Failure to maintain records for one year	Ħ	\$125.00
10-39 Fire alarm verification calls required		Ħ	\$125.00
10-40(a) Failure to register fire alarm system contractor		Ħ	\$125.00
10-40(b)	Fire alarm system contractor status required	Ħ	\$125.00
10-40(c)	Identification cards required	Ŧ	\$50.00
10-40(d)	Failure to meet UL or NVPA 72 standards	Ħ	\$125.00
10-40(e)	Activating or servicing unpermitted alarm system	Ħ	\$125.00
10-70(b)	Failure to obtain burning permit — Residential	Ι	\$75.00
10-70(b)	Failure to obtain burning permit — Commercial	II	\$150.00
10-70(d)	Failure to obtain burning permit — Boiler	I	\$75.00
10-71	Failure to obtain burn permit — Pyrotechnic	II	150.00
Chapter 10	NFPA 101 Chapters 5, 6, 7 SFPC Chapters 6, 8, 31 and 42	Ŧ¥	\$200.00

1

2

Section 2. Section 10-9 of the Code of Ordinances is amended as follows.

3 Sec. 10-9. – Florida Fire Prevention Code and Life Safety Code adopted.

4

5 The Florida Fire Prevention Code and the Life Safety Code adopted by the State Fire Marshal,

6 which shall operate in conjunction with the Florida Building Code, are hereby adopted for the

7 purpose of prescribing regulations governing conditions hazardous to life and property from fire

and explosion, as fully as if set out at length herein. Except as modified in this chapter, the
provisions herein adopted shall be controlling within the corporate limits of the city. The

provisions herein adopted shall be controlling within the corporate limits of the city. The
 minimum fire safety codes shall not apply to buildings and structures subject to the uniform fire

safety standards under F.S. § 633.206022, and buildings and structures subject to the minimum

12 fire safety standards adopted pursuant to F.S. § 394.879.

13 Section 3. Section 10-10 of the Code of Ordinances is deleted and replaced as follows to

14 adopt a local amendment to the Florida Fire Prevention Code.

15 Sec. 10-10. - Amendments to NFPA 1 Section 13.1.3 of the Florida Fire Prevention Code.

16

17 NFPA 1 Section 13.1.3 is amended by adding the following:

18 *Interfering with fire hydrants prohibited; exception.* It shall be unlawful for any person to

19 interfere with the fire hydrants in the city by unscrewing the caps on same or by taking water

1	therefrom for private or personal use, except with the written consent of the fire chief.		
2 3 4	Sec. 10-10 Amendments to NFPA 1 Section 13.1.3 of the Florida Fire Prevention Code.		
5	NFPA 1 Section 13.1.3 is amended by adding the following:		
6 7 8	<i>Interfering with fire hydrants prohibited; exception.</i> It shall be unlawful for any person to interfere with the fire hydrants in the city by unscrewing the caps on same or by taking water therefrom for private or personal use, except with the written consent of the fire chief.		
9	Section 4. Section 10-11 of the Code of Ordinances is deleted and replaced as follows to		
10	adopt a local amendment to the Florida Fire Prevention Code.		
11 12	Sec. 10-11 Amendments to NFPA 1 Section 18.3.3 of the Florida Fire Prevention Code.		
13	NFPA 1 Section 18.3.3 is amended by adding the following:		
14 15 16	(1) Every water supply for fire protection use shall be designed and installed in accordance with the Gainesville Regional Utilities' "Potable Water, Wastewater & Reclaimed Water Design Standards and Construction Details, and Material Standards Manual."		
17 18 19 20 21 22 23 24 25 26 27 28 29 30 31	 (2) The fire protection water supply for a building equipped with an automatic fire sprinkler system shall be designed and installed so as to provide an adequate fire flow in accordance with section 18.4 of the 2009 edition of NFPA 1. The fire protection water supply for a building not equipped with an automatic fire sprinkler system shall be designed and installed so as to provide an adequate fire flow in accordance with the greater requirement of either section 18.4 of the 2009 edition of NFPA 1, or the 2008 edition of the Guide for Determination of Required Fire Flow, published by Insurance Service Office. One copy of the ISO guide and one copy of section 18.4 of the 2009 edition of NFPA 1 have been deposited in the office of the city clerk and shall be kept in that office for public use, inspection and examination. The provisions of this subsection notwithstanding, the fire flow requirements may be varied at the discretion of the fire chief, or designee, if such official finds that adequate fire protection can be provided without such fire flow and/or the building is provided by the central water distribution (3). 		
32 33	system, it shall be separate and distinct from any domestic water supply provided by the central water distribution system.		
34 35 36 37 38 39	(4) The installation of the fire protection water supply shall be coordinated with the installation of other underground utilities to be located on the property. A water supply for fire protection, either temporary or permanent, shall be made available as soon as combustible material accumulates. Where underground water mains and hydrants are to be provided, they shall be installed, completed, and in service prior to building construction work.		

1 2 3 4	(5)	Where the fire protection water supply is provided by an extension of the central water distribution system, the extension, if approved and accepted by GRU, shall be conveyed to the city, at no cost to the city, together with any necessary easements to permit city maintenance of the water supply.
5 6 7	(6)	All costs associated with the construction and installation of a water distribution system extension, including the cost of inspection services performed by the city, shall be paid in full by the owner or developer prior to acceptance of the extension by the city.
8 9 10 11 12 13 14 15	(7)	The number of fire hydrants required for a project will be determined based on the fire flow demand calculations identified in (2) above. One hydrant will be required for each 1,000 GPM of demand, with at least one hydrant located within 500 feet of the most remote point of the building, as the fire truck drives. The remaining hydrants shall be located within 1,000 feet of the most remote point of the building, as the fire hydrant standards of this section and the Gainesville Regional Utilities' "Potable Water, Wastewater & Reclaimed Water Design Standards and Construction Details, and Material Standards Manual."
16 17 18 19	(8)	The provisions in subsection (7) notwithstanding, the fire hydrant requirements may be varied at the discretion of the fire chief if such official or their designee finds that adequate fire protection can be provided from an approved fire hydrant which does not meet such requirements and/or a fully automatic fire extinguishing system.
20 21 22	(9)	No hydrant shall be installed that is not capable of providing at minimum a 1,000 GPM or greater flow. The water distribution system supplying the hydrants must be capable of providing at minimum a 1,500 GPM or greater flow.
23 24 25 26	(10)	Cost of reconstruction. Where a portion of the central water distribution system must be reconstructed to meet the requirements of this section, the owner or developer will be assessed any costs incurred by the city in accordance with section 27 99 of the City of Gainesville Code of Ordinances.
27 28 29	(11)—	Access during construction or alteration. During construction or alteration of any building, access to the building and any hydrant which serves any portion of the building shall be provided for fire protection purposes without interference or obstruction.
30 31 32 33 34 35 36 37	(12)	Prohibitions. It shall be unlawful for any person to construct, or cause to be constructed, any building which does not meet the requirements of this section unless the requirements have been varied by the fire chief designated in this article as being authorized to vary such requirements. It shall also be unlawful to alter, cause to be altered, occupy or allow to be occupied any building constructed after August 10, 1981, which does not meet the requirements of this section unless the requirements have been varied as provided in this section.
37 38 39		<u>0-11 Amendments to NFPA 1 Sections 18.3, 18.4, and 18.5 of the Florida Fire</u> ntion Code.
40 41	<u>NFPA</u>	1 Sections 18.3, 18.4, and 18.5 are amended by adding the following:

1 2 3	<u>(1)</u>	Every water supply for fire protection use shall be designed and installed in accordance with the Gainesville Regional Utilities "Potable Water, Wastewater & Reclaimed Water Design Standards and Construction Details, and Material Standards Manual."
3 4 5 6 7 8 9 10 11 12 13 14 15 16	(2)	Design Standards and Construction Details, and Material Standards Manual. The fire protection water supply for a building equipped with an automatic fire sprinkler system shall be designed and installed so as to provide an adequate fire flow in accordance with Section 18.4 of the 2012 edition of NFPA 1. The fire protection water supply for a building not equipped with an automatic fire sprinkler system shall be designed and installed so as to provide an adequate fire flow in accordance with the greater requirement of either Section 18.4 of the 2012 edition of NFPA 1, or the 2008 edition of the Guide for Determination of Required Fire Flow, published by Insurance Service Office. One copy of the ISO guide and one copy of Section 18.4 of the 2012 edition of NFPA 1 shall be kept in the office of the City Clerk for public use, inspection and examination. The provisions of this subsection notwithstanding, the fire flow requirements may be varied at the discretion of the Fire Chief or designee if such official finds that adequate fire protection can be provided without such fire flow and/or the building is provided with a fully automatic fire extinguishing system.
17 18 19	<u>(3)</u>	Where the fire protection water supply is not provided by the central water distribution system, it shall be separate and distinct from any domestic water supply provided by the central water distribution system.
20 21 22 23 24 25	<u>(4)</u>	The installation of the fire protection water supply shall be coordinated with the installation of other underground utilities to be located on the property. A water supply for fire protection, either temporary or permanent, shall be made available as soon as combustible material accumulates. Where underground water mains and hydrants are to be provided, they shall be installed, completed, and in service prior to building construction work.
26 27 28 29	<u>(5)</u>	Where the fire protection water supply is provided by an extension of the central water distribution system, the extension, if approved and accepted by GRU, shall be conveyed to the city, at no cost to the city, together with any necessary easements to permit city maintenance of the water supply.
30 31 32	<u>(6)</u>	All costs associated with the construction and installation of a water distribution system extension, including the cost of inspection services performed by the city, shall be paid in full by the owner or developer prior to acceptance of the extension by the city.
33 34 35 36 37 38 39 40	<u>(7)</u>	The number of fire hydrants required for a project will be determined based on the fire flow demand calculations identified in (2) above. One hydrant will be required for each 1,000 GPM of demand, with at least one hydrant located within 500 feet of the most remote point of the building, as the fire truck drives. The remaining hydrants shall be located within 1,000 feet of the most remote point of the building, as the fire truck drives. All fire hydrants shall meet the fire hydrant standards of this section and the Gainesville Regional Utilities "Potable Water, Wastewater & Reclaimed Water Design Standards and Construction Details, and Material Standards Manual."
41 42	<u>(8)</u>	The provisions in subsection (7) notwithstanding, the fire hydrant requirements may be varied at the discretion of the Fire Chief or designee if adequate fire protection can be

6

1 2		provided from an approved fire hydrant that does not meet such requirements and/or a fully automatic fire extinguishing system.
3 4 5	<u>(9)</u>	No hydrant shall be installed that is not capable of providing at minimum a 1,000 GPM or greater flow. The water distribution system supplying the hydrants must be capable of providing at minimum a 1,500 GPM or greater flow.
6 7 8 9	<u>(10)</u>	Cost of reconstruction. Where a portion of the central water distribution system must be reconstructed to meet the requirements of this section, the owner or developer will be assessed any costs incurred by the city in accordance with Section 27-99 of the City of Gainesville Code of Ordinances.
10 11 12	<u>(11)</u>	Access during construction or alteration. During construction or alteration of any building, access to the building and any hydrant that serves any portion of the building shall be provided for fire protection purposes without interference or obstruction.
13 14 15 16 17 18 19	(12)	Prohibitions. It shall be unlawful for any person to construct, or cause to be constructed, any building that does not meet the requirements of this section unless the requirements have been varied by the Fire Chief designated in this article as being authorized to vary such requirements. It shall also be unlawful to alter, cause to be altered, occupy or allow to be occupied any building constructed after August 10, 1981, that does not meet the requirements of this section unless the requirements have been varied as provided in this section.
20		Section 5. Section 10-12 of the Code of Ordinances is deleted and replaced as follows to
21	adopt	a local amendment to the Florida Fire Prevention Code.
21 22	-	a local amendment to the Florida Fire Prevention Code. 0-12. – Amendments to NFPA 1 Section 18.3.6 of the Florida Fire Prevention Code.
	Sec. 1	
22	Sec. 1 NFPA	0-12. – Amendments to NFPA 1 Section 18.3.6 of the Florida Fire Prevention Code.
22 23	Sec. 1 NFPA	0-12. – Amendments to NFPA 1 Section 18.3.6 of the Florida Fire Prevention Code. 1 Section 18.3.6 is amended by adding the following:
22 23 24 25 26	Sec. 1 NFPA	 0-12. – Amendments to NFPA 1 Section 18.3.6 of the Florida Fire Prevention Code. 1 Section 18.3.6 is amended by adding the following: required, protective posts shall meet the following minimum requirements: a. Be a minimum of three inch diameter schedule 40 PVC or three inch diameter steel pipe set in 36 inches depth of concrete at least 15 inches in diameter. The
22 23 24 25 26 27	Sec. 1 NFPA	 0-12. – Amendments to NFPA 1 Section 18.3.6 of the Florida Fire Prevention Code. 1 Section 18.3.6 is amended by adding the following: required, protective posts shall meet the following minimum requirements: a. Be a minimum of three inch diameter schedule 40 PVC or three inch diameter steel pipe set in 36 inches depth of concrete at least 15 inches in diameter. The inside of the pipe shall be filled with solid concrete.
22 23 24 25 26 27 28	Sec. 1 NFPA	 0-12. – Amendments to NFPA 1 Section 18.3.6 of the Florida Fire Prevention Code. 1 Section 18.3.6 is amended by adding the following: required, protective posts shall meet the following minimum requirements: a. Be a minimum of three inch diameter schedule 40 PVC or three inch diameter steel pipe set in 36 inches depth of concrete at least 15 inches in diameter. The inside of the pipe shall be filled with solid concrete. b. Be located at least three feet from the fire hydrant.
22 23 24 25 26 27 28 29	Sec. 1 NFPA	 0-12. — Amendments to NFPA 1 Section 18.3.6 of the Florida Fire Prevention Code. 1 Section 18.3.6 is amended by adding the following: required, protective posts shall meet the following minimum requirements: a. Be a minimum of three inch diameter schedule 40 PVC or three inch diameter steel pipe set in 36 inches depth of concrete at least 15 inches in diameter. The inside of the pipe shall be filled with solid concrete. b. Be located at least three feet from the fire hydrant. c. Extend above ground to a minimum of fire hydrant height.
 22 23 24 25 26 27 28 29 30 	Sec. 1 NFPA When	 0-12. — Amendments to NFPA 1 Section 18.3.6 of the Florida Fire Prevention Code. 1 Section 18.3.6 is amended by adding the following: required, protective posts shall meet the following minimum requirements: a. Be a minimum of three inch diameter schedule 40 PVC or three inch diameter steel pipe set in 36 inches depth of concrete at least 15 inches in diameter. The inside of the pipe shall be filled with solid concrete. b. Be located at least three feet from the fire hydrant. c. Extend above ground to a minimum of fire hydrant height.
22 23 24 25 26 27 28 29 30 31	Sec. 1 NFPA When	 0-12. – Amendments to NFPA 1 Section 18.3.6 of the Florida Fire Prevention Code. 1 Section 18.3.6 is amended by adding the following: required, protective posts shall meet the following minimum requirements: a. Be a minimum of three inch diameter schedule 40 PVC or three inch diameter steel pipe set in 36 inches depth of concrete at least 15 inches in diameter. The inside of the pipe shall be filled with solid concrete. b. Be located at least three feet from the fire hydrant. c. Extend above ground to a minimum of fire hydrant height. d. Be spaced a minimum of three linear feet to protect the fire hydrant.

1 2 3	a. Be a minimum of three-inch diameter schedule 40 PVC or three-inch diameter steel pipe set in 36 inches depth of concrete at least 15 inches in diameter. The inside of the pipe shall be filled with solid concrete;
4	b. Be located at least three feet from the fire hydrant;
5	c. Extend above ground to a minimum of fire hydrant height; and
6	d. Be spaced a minimum of three linear feet to protect the fire hydrant.
7	Section 6. Section 10-13 of the Code of Ordinances is deleted and replaced as follows to
8	adopt a local amendment to the Florida Fire Prevention Code.
9	Sec. 10-13. – Amendments to NFPA 1 Section 18.4.5 of the Florida Fire Prevention Code.
10	NFPA 1 Section 18.4.5 is amended by adding the following:
11 12 13	The Authority Having Jurisdiction (AHJ) reserves the right to establish needed fire flow for structures not meeting the definition of a building in NFPA 1 Section 3.3.27 that based upon stock, supplies, equipment, or content, presents a significant fire suppression load.
14	
15	Sec. 10-13. – Amendments to NFPA 1 Section 18.4.5 of the Florida Fire Prevention Code.
16	NFPA 1 Section 18.4.5 is amended by adding the following:
16 17 18 19	 NFPA 1 Section 18.4.5 is amended by adding the following: The Authority Having Jurisdiction (AHJ) reserves the right to establish needed fire flow for structures not meeting the definition of a building in NFPA 1 Section 3.3.30 that based upon stock, supplies, equipment, or content, presents a significant fire suppression load.
17 18	The Authority Having Jurisdiction (AHJ) reserves the right to establish needed fire flow for structures not meeting the definition of a building in NFPA 1 Section 3.3.30 that based upon
17 18 19 20 21	The Authority Having Jurisdiction (AHJ) reserves the right to establish needed fire flow for structures not meeting the definition of a building in NFPA 1 Section 3.3.30 that based upon stock, supplies, equipment, or content, presents a significant fire suppression load.
17 18 19 20	The Authority Having Jurisdiction (AHJ) reserves the right to establish needed fire flow for structures not meeting the definition of a building in NFPA 1 Section 3.3.30 that based upon stock, supplies, equipment, or content, presents a significant fire suppression load. Section 7. Section 10-15 of the Code of Ordinances is amended as follows.
17 18 19 20 21 22 23	The Authority Having Jurisdiction (AHJ) reserves the right to establish needed fire flow for structures not meeting the definition of a building in NFPA 1 Section 3.3.30 that based upon stock, supplies, equipment, or content, presents a significant fire suppression load. Section 7. Section 10-15 of the Code of Ordinances is amended as follows. Sec. 10-15 Definitions. [The following words, terms and phrases, when used in this article, shall have the meanings
17 18 19 20 21 22 23 24 25 26	 The Authority Having Jurisdiction (AHJ) reserves the right to establish needed fire flow for structures not meeting the definition of a building in NFPA 1 Section 3.3.30 that based upon stock, supplies, equipment, or content, presents a significant fire suppression load. Section 7. Section 10-15 of the Code of Ordinances is amended as follows. Sec. 10-15 Definitions. [The following words, terms and phrases, when used in this article, shall have the meanings ascribed to them in this section, except where the context clearly indicates a different meaning.] <i>Emergency vehicle</i> means any marked or unmarked police cars or vans, fire trucks, fire rescue vehicle, emergency rescue vehicles, fire staff vehicles, ambulances and ambulance staff

1 2	<i>Residential development</i> does not include individual homes or one- and two-family occupancies with individual gates.			
3 4 5	<i>Restricted access occupancy</i> means any multiple residential occupancy with interior corridors for access to the individual residential units and restricted access <u>thatwhich</u> prevents the general public from accessing the interior corridors.			
6	Section 8. Section 10-16 of the Code of Ordinances is amended as follows.			
7 8 9		0-16 Uniform emergency access to gated developments and restricted access pancies.		
10 11 12	(a)	Each new or existing residential <u>or commercial</u> development , or business occupancy, <u>that</u> <u>has</u> access to which is limited by <u>any security gates or</u> gates <u>thatwhich</u> are not attended on a 24-hour basis, shall install an emergency vehicle access system as herein designated.		
13 14 15	(b)	Each new or existing restricted access occupancy, which <u>that</u> does not have a person on premises 24 hours a day to provide access, shall install an emergency access system as herein designated. <u>a Knox Box keyed with the City of Gainesville system code.</u>		
16		Section 9. Section 10-17 of the Code of Ordinances is amended as follows.		
17	Sec. 1	10-17. – Emergency access system.		
18	(a)	Equipment. An emergency access system shall consist of:		
19 20 21 22 23		 An alarmed lock box Knox Box, keyed with the City of Gainesville system code and containing which contains a key to the building, that shall be affixed to the building in a location approved by the fire official; or Opticom technology or and compatible technology or other emergency access technology approved by Gainesville Fire Rescue. 		
24 25	(b)	<i>Personnel.</i> The fire official shall develop and administer procedures to assure the security of the emergency access system.		
26	Section 10. Section 10-18 of the Code of Ordinances is deleted in its entirety as follows,			
27	and S	ections 10-19 and 10-20 shall be renumbered accordingly.		
28	Sec. 1	10-18. Time for compliance.		
29 30 31 32	(a)	An existing gated development shall install an emergency vehicle access system on or before October 1, 2004. Gated developments that are completed after October 1, 2002, shall install an emergency vehicle access system prior to or concurrent with the installation of a security gate.		
33 34	(b)	An existing restricted access occupancy shall install an emergency lock box access system on or before October 1, 2003. Restricted access occupancy that is completed after		

9

- October 1, 2002, shall install an emergency lock box access system prior to or concurrent
 with installation of the restricted access device.
- 3 (c) For purposes of this article, a gated development or restricted access occupancy shall be
 4 considered an existing development or building if it has obtained "final site plan
 5 approval" as defined in chapter 30 of this Code, prior to September 10, 2002.
- 6 **Section 11.** Section 10-36 of the Code of Ordinances is amended as follows.

7 Sec. 10-36. – Response to fire alarm.

16

25

- 8 (a) The fire alarm operator or an authorized responder listed on the alarm permit shall 9 respond to the fire alarm site within 30 minutes from the time of notification by the fire department of the activation of the fire alarm, whether false or not. The failure to 10 respond, when requested by the fire department, shall be deemed a violation by the fire 11 alarm operator, and fee shall be assessed in accordance with the fee schedule established 12 13 in Appendix A. The fire alarm operator shall repair a fire alarm system that is not operating properly and shall establish a fire watch until repairs are completed and 14 confirmed by the authority having jurisdiction. 15
- 17 (b) Unless the fire alarm monitoring company has verified the false fire alarm and has 18 notified the fire department prior to dispatch, it shall be unlawful for an activated fire 19 alarm system to be reset by any person prior to the arrival of a member of the fire 20 department and the department's determination of the apparent cause of the alarm 21 activation. The resetting of an activated false alarm shall be assessed with a fine in 22 accordance with the fee schedule established at Appendix A.
- 23 Section 12. Section 10-38 of the Code of Ordinances is amended as follows.
- 24 Sec. 10-38. Fire alarm monitoring companies.
- 26 (a) All fire alarm monitoring companies shall register annually with the fire alarm 27 administrator. Each fire alarm monitoring company shall pay a fee in accordance with the 28 fee schedule established at Appendix A unless it is regulated by the department of 29 business and professional regulation and has paid a local business tax for the current year 30 to the county or municipality in the state where its permanent business location or branch 31 office is maintained. Each registration shall be valid for 12 months. Failure to register, or 32 pay a fee, if applicable, shall result in a fine levied in accordance with the fee schedule 33 established at Appendix A.
- 34 (b) The fire alarm monitoring company shall provide the following information:
- 35 (1) Name, street address and telephone number of the fire alarm monitoring
 36 company;
- 37 (2) The names, street addresses and telephone numbers of all fire alarm operators
 38 contracted with within the territorial jurisdiction of this article;

1 2		(3) The procedure used to verify the legitimacy of a fire alarm prior to notification to the fire department;
3		(4) The name, street address and telephone number of the qualifying agent- <u>; and</u>
4 5		(5) Updated customers' telephone numbers for responsible key holder. Must meet the thirty (30) minute response time as provided in Section 10-36.
6 7	(c)	Upon registration, the fire alarm monitoring company shall be provided with a telephone number for use when reporting a fire alarm.
8 9 10	(d)	Fire alarm monitoring companies shall maintain records relating to fire alarm notification for a period of at least two years, and shall provide such records to the fire alarm administrator upon request.
11 12	(e)	Fire alarm monitoring companies shall monitor in accordance with the Florida Fire Prevention Code.
13 14	(f)	Failure to comply with subsection (a), (b), (d) or (e) of this section shall result in a fine being levied in accordance with the schedule established at Appendix A.
15		Section 13. Section 10-40 of the Code of Ordinances is amended as follows.
16 17	Sec. 1	10-40 Fire alarm system contractors.
18 19 20 21 22 23 24 25	(a)	All fire alarm system contractors shall register annually with the fire alarm administrator. Each fire alarm system contractor shall pay a fee in accordance with the fee schedule established at Appendix A unless it is regulated by the department of business and professional regulation and has paid a local business tax for the current year to the county or municipality in the state where it's permanent business location or branch office is maintained. Each registration shall be valid for 12 months. Failure to register, or pay a fee if applicable, shall result in a fine levied in accordance with the fee schedule established at Appendix A.
26 27 28	(b)	No person shall install, maintain, repair, alter, service or monitor fire alarm systems for compensation without being a <u>licensed</u> fire alarm system contractor <u>in the State of Florida</u> , or a fine shall be levied as established at Appendix A.
29 30 31	(c)	All <u>licensed</u> fire alarm system contractors shall furnish each of its agents with identification cards in accordance with F.S. <u>§ Chapter</u> 489, or a fine shall be levied for each violation in accordance with the fee schedule established at Appendix A.
32 33 34 35 36 37	(d)	Fire alarm system contractors shall install systems or equipment and use methods of installation that meet or exceed minimum Underwriters Laboratories or National Fire Protection Association 72 requirements for the appropriate installation and use control panels tested for conformance to the Security Industry Association's Control Panel Standard, or a fine shall be levied for each violation, in accordance with the fee schedule established at Appendix A.
38 39 40	(e)	Fire alarm system contractors shall not activate or service an alarm system unless it is permitted, or a fine shall be levied in accordance with the fee schedule established at Appendix A.

- 1 (f) Fire alarm contractors shall not cause a false alarm during the servicing, repairing, testing 2 or inspection of an alarm system. The fire alarm operator shall not be charged with such 3 false alarms.
- 4 (g) Fire alarm contractors shall provide all fire alarm operators with an <u>a valid</u> alarm permit
 5 application, whenever installing, maintaining, repairing, altering or servicing a fire alarm
 6 system., unless the fire alarm contractor reasonably believes that the fire alarm operator
 7 already holds a valid permit.
- 8 Section 14. Section 10-41 of the Code of Ordinances is amended as follows.

9 Sec. 10-41. – Prohibited fire alarm devices.

10 It is unlawful for a person to operate a fire alarm system equipped with an automatic dialing 11 device programmed to connect directly to the fire department or public safety combined 12 communications center. All automatic dialing systems <u>and radio systems</u> shall communicate fire 13 alarm notifications to a person who has accepted the responsibility of relaying the fire alarm or to 14 a business licensed by the State of Florida to engage in the relaying of fire alarm notifications. A 15 fine shall be levied in accordance with the fee schedule established at Appendix A for violation 16 of this subsection.

17 **Section 15.** Section 10-50 of the Code of Ordinances is amended as follows.

18 Sec. 10-50. – Definitions.

19 The following words, terms and phrases, when used in this article, shall have the meanings 20 ascribed to them in this section, except where the context clearly indicates a different meaning:

Assembly occupancy owner shall refer to the owner of the business providing direct
 services relating to the activities that occur within the building, and shall refer to the owner of the
 property that may have leased the structure to the individual owning the business.

Crowd manager, as required by section 20.1.5.6, NFPA 1, means an individual who has
 successfully completed a crowd manager program, approved by the Gainesville Fire Rescue
 Department, and has obtained an official identification card.

Emergency evacuation alert network means an automated system to alert patrons to an
 emergency, adequate to be heard and effective by a person of normal sensitivity, especially in
 relation to the level of noise and distraction accompanying the event.

- 30 *Fire department connection* means a connection to the automatic sprinkler system or 31 standpipe system of a structure that is utilized by fire rescue to provide additional water pressure 32 for the system to work at capacity due to hose streams or inadequate supply.
- 33 Section 16. Section 10-51 of the Code of Ordinances is amended as follows.
- 34 Sec. 10-51. Requirements for assembly occupancy owners and crowd managers.

- 1 (a) Each assembly occupancy owner shall ensure: that a credentialed crowd manager is on 2 duty when 50 or more for every 250 individuals are present within their a facility or 3 special permitted area (unless exempt), and that an additional crowd manager(s) is on 4 duty when an occupancy reaches 250 and for every additional 250 thereafter. Each 5 assembly occupancy owner shall ensure that all crowd managers are and the crowd manager is equipped with the supplies listed within subsections (b) and (c) of this section, 6 7 and shall ensure that the crowd manager(s) is ensuring compliance with subsections (d), 8 (e), and (f) of this section.
- 9 (b) Each crowd manager on duty <u>shall must</u> have a valid GFR Risk Reduction Bureau issued 10 crowd manager identification card available on premises and a counting device for 11 keeping track of the occupant load.
- (c) Each crowd manager, designated by the assembly owner, shall ensure an accurate count
 of occupant load is maintained at all times the business is open to the public, for the
 purpose of preventing overcrowding.
- 15 (d) Each crowd manager, designated by the assembly owner, shall ensure all exits are open and free of obstruction.
- 17 (e) Each crowd manager, designated by the assembly owner, shall ensure a mechanism for
 18 alerting the crowd and providing evacuation instructions are operational and available for
 19 use.
- 20(f)Each crowd manager, designated by the assembly owner, shall ensure, based upon21maintaining an accurate crowd count, to ensure that overcrowding is avoided does not22occur.
- 23 Section 17. Section 10-61 of the Code of Ordinances is amended as follows.
- 24 Sec. 10-61. Applicability; exceptions.
- 25 This article applies to all outdoor burning and open burning within the City of Gainesville,
- 26 except the following:
- 27 (a) Grilling or cooking food using charcoal, wood, propane or natural gas in cooking or
 28 grilling appliances.
- (b) The use of propane, acetylene, natural gas, gasoline or kerosene in a device <u>that is third</u>
 30 <u>party tested and</u> intended for heating, construction or maintenance activities.
- 31 Section 18. Section 10-63 of the Code of Ordinances is amended as follows.

32 Sec. 10-63. – General prohibition on outdoor burning and open burning.

- 33 Open burning and outdoor burning are prohibited in the City of Gainesville unless otherwise
- 34 specifically permitted as provided by this article. <u>Open burning of the following materials is</u>
- 35 <u>expressly prohibited and shall not be permitted:</u>

- 1(a)Open burning of rRefuse and/or household garbage.Open burning of the following2materials is prohibited.
- 3 (<u>b</u>1) Construction and demolition waste.
- 4 (<u>c</u>2) Hazardous substances including but not limited to batteries, household chemicals, 5 pesticides, used oil, gasoline, paints, varnishes, and solvents.
- 6 $(\underline{d3})$ Furniture and appliances.
- 7 (<u>e</u>4) Tires.
- 8 (<u>f</u>5) Any plastic materials including but not limited to nylon, PVC, ABS, polystyrene or 9 urethane foam, and synthetic fabrics, plastic films and plastic containers.
- 10 (g6) Newspaper.
- (<u>h</u>7) Corrugated cardboard, container board, boxes, books, magazines, printed materials, or
 office paper.
- 13 (<u>i8</u>) Treated or painted wood including but not limited to plywood, composite wood products
 14 or other wood products that are painted, varnished or treated with preservatives.
- 15 **Section 19.** Section 10-64 of the Code of Ordinances is amended as follows.

16 Sec. 10-64. – Burning of trees, logs, brush, stumps, leaves, and grass clippings.

17 Except as may be authorized by F.S. Ch. 590 and Rule 51-2, Florida Administrative Code, open burning of trees, logs, brush, stumps, leaves, and grass clippings is prohibited, except that 18 19 commercial land clearing debris burning is permitted if, prior to the burn, an application is 20 submitted with the appropriate fee and the Risk Reduction Bureau inspects the site and issues a 21 burn permit with any necessary conditions. with the use of an open pit, air curtain and 22 availability of heavy equipment provided a permit with a site visit is applied for and issued for 23 each incident. A permit may be terminated for noncompliance upon notice to the holder of the 24 permit.

25 Section 20. Section 10-66 of the Code of Ordinances is amended as follows.

26 Sec. 10-66. – Prescribed burning.

- 27 Fires set for forest, prairie, and wildlife habitant habitat management are allowed only if
- 28 conducted in accordance with F.S. §590.125 and Rule 51-2, Florida Administrative Code.
- 29 Section 21. Section 10-68 of the Code of Ordinances is amended as follows.

30 Sec. 10-68. – Patio wood-burning units.

31 A patio wood-burning unit may be installed and used in the City of Gainesville only in

- 32 accordance with all of the following provisions:
- 33 (a) The patio wood-burning unit shall not be used to burn refuse.

1 2		e patio wood-burning unit shall burn only clean wood or a commercially prepared log oduct designed for outdoor burning.
3 4	. ,	e patio wood-burning unit shall be located at least 25 feet from the nearest structure <u>twhich</u> is not on the same property as the patio wood-burning unit.
5 6		e patio wood-burning unit shall not cause a hazard or otherwise create a nuisance to ghboring property.
7 8		mmercially prepared log product shall be used in accordance with the manufacturer's ommendation.
9	See	ction 22. Appendix A Schedule of Fees, Rates and Charges is amended as
10	follows. E	Except as amended herein, the remainder of Appendix A. – Schedule of Fees, Rates and
11	Charges re	emains in full force and effect.
12	FIRE/RES	CUE:
13	(1) <i>F</i>	ire alarm operators:
14		Application for fire alarm or annual renewal application17.25
15 16		Application for fire alarm or annual renewal for integrated fire and burglar alarm system0.00
17 18 19	(2) F	(Note: proportionately adjusted for initial periods exceeding one year (section 10- 32)) <i>Calse alarms:</i>
20		First with valid permit0.00
21		First without valid permit, or second with valid permit, each129.75
22		Third and fourth, each129.75
23		Fifth, sixth and seventh, each297.75
24		Eighth and above, each749.75
25 26 27		(Note: reduced to \$11.50 if false fire alarm caused by system malfunction and proof of timely service/repair is submitted to the <u>False Alarm Reduction Unit</u> fire department (section 10-33(d))
28		Non-permitted system, additional fee243.00
29		(Note: reduced to \$61.00 if application filed within 10 days (section 10-33))
30		Fire alarm permit reinstatement fee after revocation (section 10-34)61.00
31		Failure to respond when requested by the fire department (section 10-36)61.00
32		Resetting of an activated fire alarm prior to receiving approval from the fire

15

1		department arrival of fire department and approval for resetting152.00
2		Failure to deactivate fire alarm within 15 minutes (section 10-37152.00
3		
4	(3) <i>Pro</i>	hibited devices:
5		Automatic dialing device (section 10-41 (a))152.00
6		Auxiliary power supply less than four-hour minimum (section 10-42)152.00
7	(A) E :	
8	(4) Fire	e alarm monitoring companies:
9		Annual registration fee (section 10-38)121.50
10 11		Failure to register or to maintain records for two years (section 10-38(d))152.00
12 13		Failure to monitor in accordance with the Florida Fire Prevention Code (section 10-38)152.00
14		Failure to verify alarm (section 10-39)152.00
15 16	(5) Fire	e alarm system contractors:
17		Annual registration fee (section 10-40(a))121.50
18 19 20		Failure to register annually (section 10-40(a)); failure to meet UL or NFPA 72 standards (section 10-40(d)); activation of unpermitted fire alarm (section 10-40(e))152.00
21 22		Causing false fire alarm during servicing or inspection—each violation (section 10-40(f))152.00
23 24		Installation, maintenance, repair, alteration or servicing by unregistered contractor, each violation (section 10-40(b))152.00
25 26		Failure to furnish agents with identification cards, each violation (section $10-40(c)$)61.00
27 28		Failure to provide fire alarm operators with permit applications, each violation (section $10-40(g)$)61.00
29		
30	(6) <i>Fire</i>	e inspection (Chapter 10)
31		square footage of inspected structure:
32		0—3,000 <u></u> 66.25
33		Over 3,000—5,00077.25
34		Over 5,000—10,00088.25
35		Over 10,000—50,00099.25

1	Over 50,000—100,000110.25			
2	Over 100,000—150,000121.25			
3	Over 150,000—200,000132.25			
4	Over 200,000165.50			
5				
6	(7) Burning leaves, brush, clean wood or other vegetative debris § 10-70			
7	Residential, per event55.25			
8	Commercial, per event110.25			
9 10 11 12	 (8) Annual burning permit for each burn barrel and/or outdoor wood-fired boiler § (section 10-70)55.25 			
13	(9) Pyrotechnic display $\frac{10.70}{10.70}$ 110.25			
14	Section 23. It is the intention of the City Commission that the provisions of Sections 1			
15	through 22 of this ordinance shall become and be made a part of the Code of Ordinances of the			
16	City of Gainesville, Florida, and that the sections and paragraphs of this ordinance may be			
17	renumbered or relettered in order to accomplish such intentions.			
18	Section 24. If any word, phrase, clause, paragraph, section or provision of this ordinance			
19	or the application hereof to any person or circumstance is held invalid or unconstitutional, such			
20	finding shall not affect the other provisions or applications of this ordinance that can be given			
21	effect without the invalid or unconstitutional provision or application, and to this end the			
22	provisions of this ordinance are declared severable.			
23	Section 25. All ordinances or parts of ordinances in conflict herewith are to the extent of			
24	such conflict hereby repealed.			
25	Section 26. This ordinance shall become effective immediately upon adoption.			
26				
27				

1	PASSED AND ADOPTED this	day of	, 2015.
2			
3			
4			
5		EDWARD B. BRADDY	
6		MAYOR	
7			
8			
9	Attest:	Approved as to form and le	gality:
10			
11			
12			
13	KURT M. LANNON	NICOLLE M. SHALLEY	
14	CLERK OF THE COMMISSION	CITY ATTORNEY	
15			
16	This ordinance passed on first reading this	day of	_, 2015.
17			
18	This ordinance passed on second reading this	day of	_, 2015.