
## STATE OF THE UTILITY

Item # 170652



## **OPERATIONS SUMMARY**


CORPORATE SAFETY
ENVIRONMENTAL
REGULATORY
PERSONNEL

November 2017							
Safety			Employ	vees			
Outory	(	Current Month			Year to Date		
	First Aid	Recordable	DART		First Aid	Recordable	DART
Administration	0	0	0		0	0	0
W/WW Systems	0	1	0		0	0	0
Energy Supply	0	1	0		0	1	0
Energy Delivery - Electric/Gas	0	0	0		2	1	0
GRUCom	0	0	0		0	0	0
Totals		2				2	
			V-L:-	1			
		Current Man	Vehic	<u>ies</u>		Veer to Date	
	Miles Driven	Current Mon			Miles Driven	Year to Date Recordable	Droventoble
A dualin latuation	willes Driven		Preventable		Miles Driven		Preventable
Administration		0	0		15,563		0
W/WW Systems		1	1		87,784	†	2
Energy Supply		0	0		5,332		1
Energy Delivery - Electric/Gas		0	0		129,218		ı ı
GRUCom		0	0		11,144		0
Totals		1			249,041	5	
Environmental							
		Curren	t Month	C	alendar Year to Da	te	
Notices of Violation		(	)		0		
Emissions							
DH1, DH2, DHCT3, JRKCC1							
	(tons)	77.	867		951,958		
	(tons)		16		1,136		
	(tons)		3.6		344.6		
DH Unit 2 (only)	,						
	(tons)	N	/A		25	(PM monit.OOS start 10	(17/17 )
	(lbs)	0.	46		2.04		,
<b>J</b>	,						

Personnel			
	Sum of AUTHORIZED FTE	Sum of FILLED FTE	Sum of VACANCY
GRU-Administration/ Community Relations	4.00	4.00	0.00
GRU-Administration/ COO	2.00	2.00	0.00
GRU-Administration/ Elect Reliability Compliance	2.00	2.00	0.00
GRU-Administration/ General Manager	5.00	5.00	0.00
GRU-Administration/ Legal Services	1.00	1.00	0.00
GRU-Administration/ Safety	5.00	2.00	3.00
GRU-Administration/ Training	6.00	6.00	0.00
GRU-Customer Support Services	125.25	112.25	13.00
GRU-Business Services	6.00	4.00	2.00
GRU-Communications	6.00	5.00	1.00
GRU-Energy Delivery	263.00	234.00	29.00
GRU-Energy Supply	146.00	134.00	12.00
GRU-Energy Supply/ District Energy	10.00	10.00	0.00
GRU-Electric Environmental Permitting Compliance	4.00	4.00	0.00
GRU-Finance	32.00	28.00	4.00
GRU-GRUCom	38.00	29.00	9.00
GRU-Information Technology	63.00	53.00	10.00
GRU-Water/ Wastewater	168.00	153.00	15.00
Grand Total	886.25	788.25	98.00

#### **Utility Advisory Board Monthly Report – FY 2018 Safety Data Summary**

Employee Inju	ies (DART – days away, restricted duty, temporary transfer)	
10/09/201	Puncture to chest when knife slipped from conductor.	
10/20/201	While trying to open a valve using both his hands gripped together, the emplostrained his left middle finger	yee
11/04/201	Employee lacerated his right hand and index finger on a shrp metal edge when junction box cover came loose unexpectedly.	n a
11/21/201	While cleaning the lime machine, employee had an unknown substance splash his eye causing irritation	ı in
Vehicle Collisi	ns (P) indicates preventable by our employee	
10/09/2017	imployee pulled off with bin door down and damaged another vehicle when bin door truck it. (P)	
10/18/2017	Deer ran out in front of vehicle causing damage to the front of vehicle.	
10/21/2017 Employee pulled truck forward and collided with a valve indicator post, scraping the passenger side of the truck. (P)		
10/31/2017 Employee collided with the rear of a car traveling north on Tower Road when the car stopped abruptly for a stopped car in front of him. (P)		
11/30/2017	1/30/2017 Employee was making a left turn into a shopping center for a service call. A motorcycl heading the other direction collided with the back corner of the service truck. (P)	



## **CUSTOMER SUPPORT SERVICES**

Customer Operations

New Services

Revenue Assurance

## Customer Operations Metrics Summary November 2017

Active Accounts	Nov-17	YTD Gain/Loss	FY17
Residential Contract Accounts			
Total	90,141	39	90,102
Electric	83,711	17	83,694
Gas	33,209	86	33,123
Water	62,705	13	62,692
Wastewater	58,671	11	58,660
Telecomm	131	(6)	137

New Installations	Nov-17	FY18 To Date	FY17
Electric	65	218	1545
Gas	26	82	432
Water	24	85	525
Wastewater	25	83	530
Telecomm	5	20	223

Call Center Volume	Nov-17	FY18 To Date	FY17
Average Speed of Answer	0:10:05	0:10:30	0:04:30
CSR Calls	9,139	19,212	138,716
CSR Callbacks	2,325	5,589	19,673
IVR Self Service	23,824	50,641	283,147
Total	32,963	69,853	421,863
IVR/Total	72%	72%	67%

Bills Generated	Nov-17	FY18 To Date	FY17
Paper Bills	103,799	213,276	1,245,142
eBills	15,953	32,567	191,498
Total	119,752	245,843	1,436,640
eBill/Total	13%	13%	13%

Payment Arrangements	Nov-17	FY18 To Date	FY17
Total	8,070	21,497	95,142

Active Accounts	Nov-17	YTD Gain/Loss	FY17
Nonresidential Contract Accounts			
Total	13,479	2	13,477
Electric	10,923	6	10,917
Gas	1,610	(3)	1,613
Water	5,887	(5)	5,892
Wastewater	4,657	6	4,651
Telecomm	355	2	353

Residential Disconnects	Nov-17	FY18 To Date	FY17
Volume	1,580	3,563	14,335
Average Balance	\$263.58	\$391.57	\$245.50

Revenue Assurance	Nov-17	FY18 To Date	FY17
Referred to Collections	\$157,521.64	\$359,935.33	\$2,214,584.97
Recovered	\$53,079.69	\$128,562.94	\$664,519.40

Service Orders	Nov-17	FY18 To Date	FY17
Move Ins	6,350	13,179	117,647
Move Outs	6,256	13,594	117,865

Average Res Bill Amounts	Nov-17	FY18 To Date	FY17
Electric (kWh)	689	782	804
Electric (\$)	\$104.45	\$117.30	\$117.98
Gas (Therms)	14	12	16
Gas (\$)	\$26.42	\$24.00	\$28.81
Water (kGals)	5	5	5
Water (\$)	\$31.54	\$30.85	\$31.74
Wastewater (kGals)	5	5	5
Wastewater(\$)	\$36.94	\$36.25	\$38.08

12/6/2017 VNR

## THIS PAGE INTENTIONALLY LEFT BLANK

## **ENERGY DELIVERY**

ELECTRIC T&D

SYSTEM RELIABILITY

GAS

#### Durations Reliability Report Between 11/01/2017 and 11/30/2017

Excludes Extreme Weather and Generation/Transmission Disturbances

CUSTOMER DATA	RELIABILITY INDICIES		MONTHLY AVG GOAL
Monthly Average Customers Served(C)	96,359 Average Service Availability Index (ASAI)	99.9981%	
Total Hours of Customer Demand	67,065,864 System Average Interruption Duration Index (SAIDI)	.081 Mins.	4.5 Mins
Total Number of Outages	31 Customer Average Interruption Duration Index (CAIDI)	27.58 Mins	55 Mins
Total Number of Customers Affected (CI)	2,818 System average Interruption Frequency Index (SAIFI)	0.03	0.08
Total Customer Minutes Interrupted (CMI)	77,709	_	
Total Customer "Out Minutes"	3,893 Average Length of a Service Interruption (L-Bar)	125.58 Mins	

#### **Outage Duration Times**

Average Hours: 2 Maximum Hours: 10 Minimum Hours: 0

#### **Cause of Outages**

Cause	Overhead	Underground	Undetermined	Total
1. Weather	0	0	0	0
1. Vegetation	4	0	1	5
1. Animals	11	2	0	13
Foreign Interference	0	0	0	0
1. Human Cause	3	2	0	5
1. Undetermined	1	0	0	1
Equipment Failure	1	3	3	7
All Remaining Outages	0	0	0	0
Total	20	7	4	31

#### Durations Reliability Report Between 10/01/2017 and 11/30/2017

Excludes Extreme Weather and Generation/Transmission Disturbances

CUSTOMER DATA	RELIABILITY INDICIES	MONTHLY AVG GOAL		
Monthly Average Customers Served(C)	96,359 Average Service Availability Index (ASAI)	99.9972%		
Total Hours of Customer Demand	138,756,960 System Average Interruption Duration Index (SAIDI)	2.46 Mins	4.5 Mins	
Total Number of Outages	103 Customer Average Interruption Duration Index (CAIDI)	32.52 Mins	55 Mins	
Total Number of Customers Affected (CI)	7,285 System average Interruption Frequency Index (SAIFI)	0.08	0.08	
Total Customer Minutes Interrupted (CMI)	236,900			
Total Customer "Out Minutes"	11,404 Average Length of a Service Interruption (L-Bar)	110.72 Mins		

#### **Outage Duration Times**

Average Hours: 1 Maximum Hours: 10 Minimum Hours: 0

#### **Cause of Outages**

Cause	Overhead	Underground	Undetermined	Total
1. Weather	0	0	0	0
1. Vegetation	27	2	5	34
1. Animals	18	6	0	24
1. Foreign Interference	0	0	0	0
1. Human Cause	3	3	2	8
1. Undetermined	4	3	0	7
Equipment Failure	9	10	11	30
All Remaining Outages	0	0	0	0
Total	61	24	18	103

#### **Energy Delivery - Major Design Projects - Electric**

#### Major Electric Design Projects underway:

- > Butler Plaza Town Center
- > Boulevard Station, Butler Fire Station
- > Blues Creek Unit 7 16 residential units
- > Springhill MOB Phase 2
- > Greenhouse Church
- > One College Park (apartments)
- > CRA NW 1st Ave (OH to UG conversion)
- > Ingenuity (office building)
- > Depot Ave. Phase #4 Project (relocation due to road work)
- > The Nine (apartments)

#### Major Electric Design Projects expected to start within 30 days:

- > Drury Inn & Suites 4000 SW 40 Blvd (Hotel)
- > Gloria's Way Subdivision 42 lot subdivision 900 SW 122nd Street
- > North Florida Women's Clinic 4337 NW 8th Avenue
- > CRA South Main Street (OH to UG Conversion)
- > Hub on Campus (Apartments & Retail)
- > 238 W. University Avenue (Apartments & Retail)

#### **Energy Delivery - Major Construction Projects - Gas**

#### Major Gas Design Projects:

- > Gas Construction, Engineering and Marketing reviewing options to extend gas service into Newberry.

  Reviewing and estimating costs from the Argos Line as well as from Sable Trail. Marketing preparing ROR's.
- > 300 Blk NW 15th St bare steel replacements (1,700 ft) construction plans
- > Amariah Subdivision, 4,400 ft. gas main installation County Permit Request
- > Greenhouse Church gas main crossing on NW 39th Ave, 1,600 ft. County Permit Request
- > Provide utility work schedules for the SunTrail/Tower Road drainage/resurfacing (County project)
- > Provide utility work schedules for the SE 4th Street reconstruction (City project)

New Services installed in November: 37 – New Customer work/Not replacement work

#### **Electric System Consumption**

ELECTRIC SYSTEM	CONSUMPTION	CUSTOMERS
Feed-In-Tariff - Residential	52 KWH	104
Feed-In-Tariff - General Service	2,426 KWH	157
Electric - GS - Demand - Regular	49,921,078 KWH	1,237
Electric - General Service Demand PV	657,476 KWH	15
GREC Startup Supplemental and Standby	452,351 KWH	1
Electric - GS - Kanapaha w Curtail Cr	997,200 KWH	1
Electric - GS - Demand - Large Power	8,036,440 KWH	8
Electric - GS - Murphree Curtail Credit	1,444,800 KWH	1
Electric - GS Large Demand PV	4,250,400 KWH	2
Electric - GS - Non Demand	14,168,512 KWH	9,782
Electric - General Service PV	100,591 KWH	53
Electric - Lighting - Rental	1,011,528 KWH	4,607 <i>n</i>
Electric - Lighting - Street - City	792,176 KWH	14 <i>n</i>
Electric - Lighting - Street - County	299,356 KWH	2 n
Electric - Lighting - Traffic	4,542 KWH	2 n
Electric - Residential - Non TOU	56,991,966 KWH	86,049
Electric - Residential PV	124,085 KWH	227
Total Retail Electric (n = not included in total)	139,254,979 KWH	97,637
City of Alachua	9,025,000 KWH	18,153 KW
City of Winter Park	7,200,000 KWH	10,000 KW
Total (Native) Electric	155,479,979 KWH	

#### **Gas System Consumption**

#### **GAS SYSTEM**


Gas - GS - Regular Service (Firm)	725,010 THM	1,395
Gas - GS - Regular Service (Small)	11,458 THM	257
Gas - GS - Interrruptible - Regular Serv	20,224 THM	1
Gas - GS - Interrruptible - Large Volume	421,385 THM	7
Gas - Residential - Regular Service	442,796 THM	34,008
Total Retail Gas	1,620,873 THM	35,668
Gas - GS - UF Cogeneration Plant	3,517,164 THM	1
Gas - Residential - LP - Basic Rate	3,167 GAL	196
GREC Gas (PGA Only)	13,400 THM	1


## THIS PAGE INTENTIONALLY LEFT BLANK

## **ENERGY SUPPLY**

# SYSTEM STATISTICS ENERGY DISTRIBUTION FUEL


nergy S	Supply -November 2017				
	Statistics				
		Unit Capabi	ility output - I	MWn .	
	DH-2	2	228		
	DH-1		75		
	Kelly CC	1	108		
	CT's	1	106		
	Grid	2)	( 224		
	GREC	10	02.5		
	Francis Supply - BANA/Han D				
	Energy Supply - MWHrs D	envered			
		Month	YTD	Budget YTD	Delta Budget
ource					
	DH-2	54,792	118,719	208,226	(89,507)
	DH-1	17,418	34,109	25,359	8,750
	Kelly CC	905	18,051	14,969	3,082
	CT's	218	218	-	218
	Grid	13,695	70,076	52,758	17,318
	GREC	49,589	96,752	-	96,752
	Average Energy Distribution	on Curve			
	Cumo 1 io tha karrely distrib	n of local sur-	***************************************	o moonth /D= 560	) \
	Curve 1 is the hourly distributio Curve 2 is peak load per day (Pg		rages over th	e month (Pg ESz	2)
	Curve 215 peak todu pet udy (Pg	L33)			
	Fuel Consumed				
		Month	YTD	Budget YTD	Delta Budget
	Coal - Tons	20,462	45,347	106,380	(61,033)
	Gas-MCF	464,361	996,178	580,226	415,952
	Fuel oil - Gal	-101,301	-	-	-
	. 5.5.0 • • • •				





#### Major Energy Supply Projects/Milestones Updates:

- 1. For Kelly Plant Generation Station Outage (JCC1 Outage):
  - a. The work on the combustion CT4 is on track with no significant discovery work, and expected to restore CT4 to service by 11/21/2017.
  - b. The work on Unit #8 has had significant discovery of cracking in the turbine steam chest, even more extensive that what we saw in the 2013 outage. As such we have arranged for these repairs to be done by Siemens in their Charlotte, NC Shop. The steam chest shipped on 11/4, and arrived in Charlotte on 11/5. With a 21 day weld estimate if all goes as planned Unit #8 (and hence JCC1) could be fully restored to service by mid-December.
- 2. For the South Energy Center Phase 2 project we are continuing with the electrical migration of the new Wartsilla engine (REG1) and the new 3 MW Diesel Engine (DG3. We are working diligently with the hospital to meet all the required testing and performance guarantees. As the migration testing impacts both hospitals (Cancer and Cardio/Neuro-medicine), most of the testing has had to be done after the last patient surgery at night (~10:00pm) and through the night.
- 3. The focus for last two months was on the addition of the Deerhaven Renewable to the Energy Supply Generation. At this point we are happy to report through all the efforts we are ready for this to occur as planned on 11/7/2017.




## **ENVIRONMENTAL PERMITTING**

## **EMISSIONS DATA**


	Yearly E	missions		
SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	Mercury (lbs)	PM (tons)	CO <sub>2</sub> (tons)
1,182	450	8.95	125	1,317,603
1,134	653	6.64	112	1,177,703
1,144	1,052	6.23	32	1,192,647
532	608	5.49	47	1,260,423
354	984	2.92	61	1,216,690
	1,182 1,134 1,144 532	SO <sub>2</sub> (tons) NO <sub>X</sub> (tons)  1,182 450  1,134 653  1,144 1,052  532 608	1,182     450     8.95       1,134     653     6.64       1,144     1,052     6.23       532     608     5.49	SO <sub>2</sub> (tons)         NO <sub>x</sub> (tons)         Mercury (lbs)         PM (tons)           1,182         450         8.95         125           1,134         653         6.64         112           1,144         1,052         6.23         32           532         608         5.49         47

2016 Mercury values are for Unit 2 only.




 $SO_2$  was lower in 2015 and 2016 due to higher removal rate settings to assure compliance with the MATS Rule.

 $NO_X$  was higher in 2016 since it was more cost effective to use allowances than increase SCR removal rate.



with the MATS Rule.



			Mass Emiss	sions - Last Month for 5	Years - November			
		SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	Mercury (lbs)	PM (tons)	CO <sub>2</sub> (tons)	HTIP (MMBtu)	GEN (MW-hours)
	Nov. 2013	0.2	26.6			33,669	566,548	49,175
	Nov. 2014	0.1	21.6			23,029	387,530	40,138
	Nov. 2015	8.1	26.6	0.1	0.3	52,380	851,552	96,684
	Nov. 2016	0.3	22.0	0.0	0.0	48,400	814,416	92,981
	Nov. 2017	38.6	116.3	0.5	0.0	77,867	867,651	86,646
		SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	Mercury (lbs)	PM (tons)	CO <sub>2</sub> (tons)	HTIP (MMBtu)	GEN (MW-hours)
Nov. 2013	DH1	0.1	21.8			16,495.3	277,579.0	26,146.0
	DH2	0.0	0.0			0.0	0.0	0.0
	DHCT3	0.0	0.0			150.1	2,526.0	183.0
	JRKCC1	0.1	4.8			17,023.9	286,443.0	22,846.0
	TOTAL	0.2	26.6	0.000	0.00	33,669.3	566,548.0	49,175.0
		SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	Mercury (lbs)	PM (tons)	CO <sub>2</sub> (tons)	HTIP (MMBtu)	GEN (MW-hours)
Nov. 2014	DH1	0.1	18.2			14,673.2	246,931.0	24,068.0
	DH2	0.0	0.0			0.0	0.0	0.0
	DHCT3	0.0	0.0			14.9	251.0	0.0
	JRKCC1	0.0	3.4			8,341.2	140,348.0	16,070.0
	TOTAL	0.1	21.6	0.000	0.00	23,029.3	387,530.0	40,138.0
		SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	Mercury (lbs)	PM (tons)	CO <sub>2</sub> (tons)	HTIP (MMBtu)	GEN (MW-hours)
Nov. 2015	DH1	0.1	12.8			11,521.0	193,843.0	18,780.0
	DH2	7.8	7.1	0.15	0.26	4,639.3	47,254.0	4,696.0
	DHCT3	0.0	0.2			687.9	11,576.0	914.0
	JRKCC1	0.2	6.5			35,531.7	598,879.0	72,294.0
	TOTAL	8.1	26.6	0.148	0.26	52,379.9	851,552.0	96,684.0
		/		0.0(11)	DB4 (+)			
		SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	Mercury (lbs)	PM (tons)	CO <sub>2</sub> (tons)	HTIP (MMBtu)	GEN (MW-hours)
Nov. 2016	DH1	0.1	14.0			11,894.7	200,147.0	17,278.0
	DH2	0.0	0.0	0.00	0.00	0.0	0.0	0.0
	DHCT3	0.0	0.1			581.4	9,782.0	708.0
	JRKCC1	0.2	7.9	0.000		35,924.1	604,487.0	74,995.0
	TOTAL	0.3	22.0	0.000	0.00	48,400.2	814,416.0	92,981.0
		SO (tons)	NO (tons)	Mercury (lbs)	PM (tons)	CO (tons)	LITID (NANAD+)	CENT (BA)A( barres)
Nov. 2017	DH1	<b>SO<sub>2</sub></b> (tons)	<b>NO<sub>x</sub> (tons)</b> 15.5	increary (163)	1101 (10113)	CO <sub>2</sub> (tons) 14,293.9	HTIP (MMBtu) 240,543.0	GEN (MW-hours) 19,167.0
1404. 2017	DH1 DH2	38.5	100.1	0.455	0.000	62,530.3	240,543.0 609,572.0	66,260.0
	DH2 DHCT3	38.5 0.0	0.1	0.400	0.000	62,530.3 198.8	3,345.0	66,260.0 234.0
	JRKCC1	0.0	0.1			843.6	3,345.0 14,191.0	985.0
	TOTAL	38.6	116.3	0.455	0.0	77,866.6	867,651.0	86,646.0
		-			-	,	,	

				Mass Emissions Rate - La	st Month for 5 Years per MW	/h		
		SO <sub>2</sub> lbs per MW-hr net	NO <sub>x</sub> lbs per MW-hr net	Hg lbs per MW-hr net	PM lbs per MW-hr net	CO <sub>2</sub> tons per MW-hr net	HTIP (MMBtu)	GEN (Net MW-hours)
Nov. 2013	DH1	0.00765	1.66756			0.63089	277,579.0	26,146.0
	DH2	0.00000	0.00000			0.0000	0.0	0.0
	DHCT3	0.00000	0.00000			0.82022	2,526.0	183.0
	JRKCC1	0.00875	0.42020			0.74516	286,443.0	22,846.0
		SO <sub>2</sub> lbs per MW-hr net	NO <sub>x</sub> lbs per MW-hr net	Hg lbs per MW-hr net	PM lbs per MW-hr net	CO <sub>2</sub> tons per MW-hr net	HTIP (MMBtu)	GEN (Net MW-hours)
Nov. 2014	DH1	0.00831	1.51238			0.60966	246,931.0	24,068.0
	DH2	0.00000	0.00000			0.0000	0.0	0.0
	DHCT3	0.00000	0.00000			0.0000	251.0	0.0
	JRKCC1	0.00000	0.42315			0.51905	140,348.0	16,070.0
		SO <sub>2</sub> lbs per MW-hr net	NO <sub>x</sub> lbs per MW-hr net	Hg lbs per MW-hr net	PM lbs per MW-hr net	CO <sub>2</sub> tons per MW-hr net	HTIP (MMBtu)	GEN (Net MW-hours)
Nov. 2015	DH1	0.01065	1.36315			0.61347	193,843.0	18,780.0
	DH2	3.32198	3.02385			0.98793	47,254.0	4,696.0
	DHCT3	0.00000	0.43764			0.75263	11,576.0	914.0
	JRKCC1	0.00553	0.17982			0.49149	598,879.0	72,294.0
		SO <sub>2</sub> lbs per MW-hr net	NO <sub>x</sub> lbs per MW-hr net	Hg lbs per MW-hr net	PM lbs per MW-hr net	CO <sub>2</sub> tons per MW-hr net	HTIP (MMBtu)	GEN (Net MW-hours)
Nov. 2016	DH1	0.01158	1.62056			0.68843	200,147.0	17,278.0
	DH2	0.00000	0.00000	0.000000	0.000	0.00000	0.0	0.0
	DHCT3	0.00000	0.28249			0.82119	9,782.0	708.0
	JRKCC1	0.00533	0.21068			0.47902	604,487.0	74,995.0
		SO <sub>2</sub> lbs per MW-hr net	NO <sub>x</sub> lbs per MW-hr net	Hg lbs per MW-hr net	PM lbs per MW-hr net	CO <sub>2</sub> tons per MW-hr net	HTIP (MMBtu)	GEN (Net MW-hours)
Nov. 2017	DH1	0.01043	1.61736			0.74576	240,543.0	19,167.0
	DH2	1.16209	3.02143	0.000007	0.000	0.94371	609,572.0	66,260.0
	DHCT3	0.00000	0.85470			0.84957	3,345.0	234.0
	JRKCC1	0.00000	1.21827			0.85645	14,191.0	985.0

2016	Emissions							
	SO (tons)	NO (tons)	Mercury (lbs)	PM (tons)	CO (tons)	NO Pata (Ib/mmPtu)	LITID /mama Dt)	1.4)A/ b 0.115
5114	SO <sub>2</sub> (tons)	NO <sub>X</sub> (tons)				NO <sub>X</sub> Rate (lb/mmBtu)	HTIP (mmBtu)	
DH1	2.7	161.4	NA	9.0	139,749.8	0.1340	2,349,851.0	202,123.0
DH2	349.5	737.6	2.917	29.3	683,555.8	0.2320	6,664,325.0	675,645.0
DHCT3	0.0	1.2	NA	0.3	4,737.4	0.0420	79,720.0	6,062.0
JRKCC1	2.0	83.8	NA	22.0	388,646.5	0.0260	6,539,729.0	796,347.0
TOTAL	354.2	984.0	2.917	60.6	1,216,689.5	0.434	15,633,625.0	1,680,177.0
2016 Fm	ssions per Net N	IW-hr						
2020 2	borono per riceri							
	SO <sub>2</sub> lbs/MW-hr	NO <sub>x</sub> lbs/MW-hr	Mercury (lbs)	PM (lbs)	CO <sub>2</sub> tons per MW-hr			
DH1	0.02672	1.59705	NA	0.08905	0.69141			
DH2	1.03457	2.18340	0.00000432	0.08682	1.01171			
DHCT3	0.00000	0.39591	0.000	0.09898	0.78149			
JRKCC1	0.00502	0.21046	0.000	0.05525	0.488			

					2017 (Jan-Nov)				
	SO <sub>2</sub> (tons)	NO <sub>x</sub> (tons)	Mercury (lbs)	PM (tons)	CO <sub>2</sub> (tons)	SO <sub>2</sub> Rate (lb/MMBtu)	NO <sub>x</sub> Rate (lb/MMBtu)	HTIP (MMBtu)	GEN (MW-hours)
DH1	8.1	168.7			155,367.4	2 , , , , ,	X	2,610,770.0	221,118.0
DH2	335.2	910.6	2.0	25.04	525,852.0			5,115,084.0	525,852.0
DHCT3	0.0	1.3			5,433.7			91,414.0	6,701.0
JRKCC1	1.3	54.9			265,304.5			4,464,251.0	551,294.0
TOTAL	344.6	1,135.5	2.038	25.0	951,957.6			12,281,519.0	1,304,965.0
				DH2 PM was Jan -	Oct 16 as the PM monit	or was out of service			
				2017 (J	an-Nov.) Emissions per	MW-hr			
	SO <sub>2</sub> lbs/MW-hr	NO <sub>x</sub> lbs/MW-hr	Mercury (lbs)	PM (lbs)	CO <sub>2</sub> tons/MW-hr	SO <sub>2</sub> Rate (lb/MMBtu)	NO <sub>x</sub> Rate (lb/MMBtu)	HTIP (MMBtu)	GEN (MW-hours)
DH1	0.07326	1.52588			0.70264			2,610,770.0	221,118.0
DH2	1.27488	3.46333	0.00000	0.09524	1.00000			5,115,084.0	525,852.0
DHCT3	0.00000	0.38800			0.81088			91,414.0	6,701.0
JRKCC1	0.00472	0.19917			0.48124			4,464,251.0	551,294.0

	GREC 2016 Emissions											
State	Facility Name	Facility ID (ORISPL)	Unit ID	Associated Stacks	Year	Quarter	Program(s)	SO2 (tons)	Avg. NOx Rate (lb/MMBtu)	NOx (tons)	CO2 (short tons)	leat Input (MMBtu)
FL	Gainesville Renewable Energy Center	57241	BFB1		2016	1-4	ARP	1.308	0.0685	21.148	65829.75	634316.337
		GREC 2017	Emissior	s Quarter 1-3, Janua	ry-Septe	mber 2017						
State	Facility Name	Facility ID (ORISPL)	Unit ID	Associated Stacks	Year	Quarter	Program(s)	SO2 (tons)	Avg. NOx Rate (lb/MMBtu)	NOx (tons)	CO2 (short tons)	leat Input (MMBtu)
FL	Gainesville Renewable Energy Center	57241	BFB1		2017	1	ARP	2.169	0.07	39.92	121746.132	1168275.865
FL	Gainesville Renewable Energy Center	57241	BFB1		2017	2	ARP	2.804	0.0628	47.65	158148.834	1515432.854
FL	Gainesville Renewable Energy Center	57241	BFB1		2017	3	ARP	1.116	0.0641	18.314	60780.86	583579.19

## **LEGAL EXPENSES**

Fiscal Year to Date

## **LEGAL EXPENSES FISCAL YEAR TO DATE (FY18)**

VENDOR	SPECIALITY	10/01	1-10/31 2017	11/0	1-11/30 2017	Tota	l Legal Costs
1000963 HOPPING GREEN & SAMS	Environment	\$	3,502.00	\$	5,975.75	\$	9,477.75
1001111 ORRICK HERRINGTON	Former Bond Counsel	\$	8,129.89			\$	8,129.89
1001204 HOLLAND & KNIGHT	Current Bond Counsel	\$	-	\$	520,000.00	\$	520,000.00
1005092 BRYANT MILLER OLIVE	Current Disclosure Counsel	\$	-	\$	212,500.00	\$	212,500.00
1001350 WINSTON & STRAWN	Power Purchase Agreement	\$	138,815.83	\$	25,297.88	\$	164,113.71
1001076 JOHN & HENGERER	Energy Law	\$	910.00	\$	-	\$	910.00
		\$	151,357.72	\$	763,773.63	\$	915,131.35
		Υ	101,001.172	Υ	7.55,7.5.55	Υ	313,131.03

## THIS PAGE INTENTIONALLY LEFT BLANK

## WATER/WASTEWATER

## PRODUCTION MAINTENANCE

Water/Wastewater Monthly Dashboard

	Р	roduction			
phree Water Treatment P					
			Permitted		
	November 2017	FY to Date (mgd)	Capacity (mgd)	% of Permitted Capacity	Sta
Average Daily Flow	23.4	23.7	30	79%	
Peak Daily Flow	25.9	25.9	54	-	
n Street Water Reclamatio	on Facility				
	November 2017	FY to Date (mgd)	Permitted Capacity (mgd)		Sta
Average Daily Flow	5.5	6.4	7.5		
apaha Water Reclamatio	n Facility				
	November 2017	FY to Date (mgd)	Permitted Capacity (mgd)		Sta
Average Daily Flow	11.6	12.5	14.9		
er Reclamation Facilities	(Combined)				
	November 2017	FY to Date (mgd)	Permitted Capacity (mgd)	% of Permitted Capacity	Sta
Average Daily Flow	17.1	18.9	22.4	84%	
	Ма	intenance	<u></u>		
stewater Collections					
		Nov 2017 (Miles)	FYTD	Monthly Goal (miles)	1
Miles of gravity mains clea	aned	4.8	10.1	7.5	
Miles of gravity mains TV	inspected	3.6	8.7	7.5	
er Distribution & Wastew	ater Collections				
		Nov 2017	FYTD		
Work orders, service orde	ers completed	1285	2,262		
	SSO Mo	onthly Summ			
		November	FYTD	GOAL	
		1	1		1