



## ADDENDUM NO. 5

Date: June 29, 2018

Bid Date: July 2, 2018  
at 3:00 P.M. (Local Time)

Bid Name SW 40<sup>th</sup> Extension and SW 47<sup>th</sup> Ave Trail

Bid No.: WSPP-180086-DM

NOTE: This Addendum has been issued only to the holders of record of the specifications and to the attendees of the non-mandatory pre-bid conference held on June 12, 2018.

The original Specifications remain in full force and effect except as revised by the following changes which shall take precedence over anything to the contrary:

1. The deadline for questions was June 19, 2018.
2. Please find attached:
  - a) Copy of the blackout period information (Financial Procedures Manual Section 41-423 Prohibition of lobbying in procurement matters)) distributed during mandatory pre-bid meeting.

The following are answers/clarifications to questions received after the non-mandatory pre-bid conference:

3. Question: The following notes appear on Sht #11 for the Stabilized Path.

*NOTES:*

1. STONE LAYER SHALL CONFORM TO THE FOLLOWING:
  - A. CLEAN, NON-PLASTIC AGGREGATE, FREE FROM DELETERIOUS OR FOREIGN MATTER, MANUFACTURED FROM CRUSHED ROCK OR RECLAIMED PORTLAND CEMENT CONCRETE (LIMESTONE/LIMEROCK NOT ALLOWED).
  - B. LA ABRASION PER FDOT STANDARD SPECIFICATIONS SECTION 901.
  - C. GRADATION OF STONE TO CONFORM TO FDOT STANDARD SPECIFICATIONS SECTION 901.

Are we understanding this note (A) correctly - #57 Sized Limerock is not to be used? It would appear that Granite would be the only viable alternative.

Answer: As per Note 1.A on Sheet 11, Stabilized Path Detail, Limestone/Limerock will not be allowed.

ACKNOWLEDGMENT: Each Proposer shall acknowledge receipt of this Addendum No. 5 by his or her signature below, **and a copy of this Addendum to be returned with proposal.**

CERTIFICATION BY PROPOSER

The undersigned acknowledges receipt of this Addendum No. 5 and the Proposal submitted is in accordance with information, instructions, and stipulations set forth herein.

PROPOSER: \_\_\_\_\_

BY: \_\_\_\_\_

DATE: \_\_\_\_\_

# CITY OF \_\_\_\_\_ FINANCIAL SERVICES GAINESVILLE PROCEDURES MANUAL

## **41-423      Prohibition of lobbying in procurement matters**

Except as expressly set forth in Resolution 060732, Section 10, during the black out period as defined herein no person may lobby, on behalf of a competing party in a particular procurement process, City Officials or employees except the purchasing division, the purchasing designated staff contact. Violation of this provision shall result in disqualification of the party on whose behalf the lobbying occurred.

Black out period means the period between the issue date which allows for immediate submittals to the City of Gainesville Purchasing Department for an invitation for bid or the request for proposal, or qualifications, or information, or the invitation to negotiate, as applicable, and the time the City Officials and Employee awards the contract.

Lobbying means when any natural person for compensation, seeks to influence the governmental decision making, to encourage the passage, defeat, or modification of any proposal, recommendation or decision by City Officials and Employees, except as authorized by procurement documents.