



Legislation Details

File #: 990267 **Version:** 2 **Name:** Fire Hydrant Protection Ordinance (B)
Type: Ordinance **Status:** Passed
File created: 10/11/1999 **In control:** City Attorney
On agenda: **Final action:** 10/11/1999
Title: FIRE HYDRANT PROTECTION (B)

ORDINANCE NO. 0-99-72

AN ORDINANCE OF THE CITY OF GAINESVILLE, FLORIDA, AMENDING SECTION 10-9 OF THE CODE OF ORDINANCES, TO REQUIRE THAT FIRE HYDRANTS HAVE AT LEAST A THREE (3) FOOT RADIUS CLEAR OF OBSTRUCTIONS; REQUIRING PROTECTIVE POSTS FOR CERTAIN FIRE HYDRANTS WHEN REQUIRED BY FIRE CHIEF OR DESIGNEE; PROVIDING A SCHEDULE FOR COMPLIANCE; PROVIDING DIRECTIONS TO THE CODIFIER; PROVIDING A SEVERABILITY CLAUSE; PROVIDING A REPEALING CLAUSE; AND PROVIDING AN IMMEDIATE EFFECTIVE DATE.

Sponsors:

Indexes:

Code sections:

Attachments: 1. 990267_a Second Reading Fire Hydrant Protection Ordinance_20000101, 2. 990267_b Second Reading Fire Hydrant Protection Ordinance_20000101, 3. 990267_First Reading Fire Hydrant Protection Ordinance_20000101

Date	Ver.	Action By	Action	Result
10/11/1999	2	City Commission	Adopted on Final Reading (Ordinance)	Pass
9/27/1999	1	City Commission	Adopted on First Reading (Ordinance)	Pass
7/26/1999	0	City Commission	Approved as Recommended	Pass