



Legislation Details

**File #:** 990267      **Version:** 2      **Name:** Fire Hydrant Protection Ordinance (B)  
**Type:** Ordinance      **Status:** Passed  
**File created:** 10/11/1999      **In control:** City Attorney  
**On agenda:**      **Final action:** 10/11/1999  
**Title:** FIRE HYDRANT PROTECTION (B)

ORDINANCE NO. 0-99-72

AN ORDINANCE OF THE CITY OF GAINESVILLE, FLORIDA, AMENDING SECTION 10-9 OF THE CODE OF ORDINANCES, TO REQUIRE THAT FIRE HYDRANTS HAVE AT LEAST A THREE (3) FOOT RADIUS CLEAR OF OBSTRUCTIONS; REQUIRING PROTECTIVE POSTS FOR CERTAIN FIRE HYDRANTS WHEN REQUIRED BY FIRE CHIEF OR DESIGNEE; PROVIDING A SCHEDULE FOR COMPLIANCE; PROVIDING DIRECTIONS TO THE CODIFIER; PROVIDING A SEVERABILITY CLAUSE; PROVIDING A REPEALING CLAUSE; AND PROVIDING AN IMMEDIATE EFFECTIVE DATE.

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. 990267\_a Second Reading Fire Hydrant Protection Ordinance\_20000101, 2. 990267\_b Second Reading Fire Hydrant Protection Ordinance\_20000101, 3. 990267\_First Reading Fire Hydrant Protection Ordinance\_20000101

Date	Ver.	Action By	Action	Result
10/11/1999	2	City Commission	Adopted on Final Reading (Ordinance)	Pass
9/27/1999	1	City Commission	Adopted on First Reading (Ordinance)	Pass
7/26/1999	0	City Commission	Approved as Recommended	Pass